

CERTIFICATE

No. U6 097386 0696 Rev. 00

Holder of Certificate: **LEDVANCE GmbH**
Parkring 1-5
85748 Garching
GERMANY

Certification Mark:




Product: **Luminaires for emergency lighting
(LED Fixed luminaires)**

The product was voluntarily tested according to the listed standards. The product can be marked with the certification mark shown above. It is not permitted to alter the certification mark in any way. In addition, the certificate holder must not transfer the certificate to third parties. All applicable requirements of the Testing, Certification, Validation and Verification Regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: 64142255000501

Date, 2025-06-25



(Taylor Yao)

CERTIFICATE

No. U6 097386 0696 Rev. 00

Model(s):
DP FLEX DA 1200 P 34W 830 IP66;
DP FLEX DA 1200 P 34W 840 IP66;
DP FLEX DA 1200 P 34W 865 IP66;
DP FLEX DA 1500 P 42W 830 IP66;
DP FLEX DA 1500 P 42W 840 IP66;
DP FLEX DA 1500 P 42W 865 IP66

Brand Name: LEDVANCE



Parameters:

Rated Voltage: 220-240VAC/DC
Rated Frequency: 0/50/60Hz
Rated Power: See below table for details
Protection Class: II
Degree of Protection: IP66
Blue Light Risk Group: RG0
ta: 50°C

Model No.	Rated Power (W)
DP FLEX DA 1200 P 34W 830 IP66	34
DP FLEX DA 1200 P 34W 840 IP66	34
DP FLEX DA 1200 P 34W 865 IP66	34
DP FLEX DA 1500 P 42W 830 IP66	42
DP FLEX DA 1500 P 42W 840 IP66	42
DP FLEX DA 1500 P 42W 865 IP66	42

Tested according to:
EN IEC 60598-2-22:2022
EN 60598-2-24:2013
EN IEC 60598-2-1:2021
EN IEC 60598-1:2021/A11:2022

Production Facility(ies): 101065, 001465