






Lampenverdrahtung / Lamp wiring:



Max. zulässige Leitungslänge zwischen EVG und Lampe: < 1,0 m (PIN 1, 2); < 0,5 m (PIN 3, 4)

Max. permissible cable length between ECG and lamp: < 1.0 m (PIN 1, 2); < 0.5 m (PIN 3, 4)