

CEC Title 24 (CEC-400-2018-021-CMF 2019
REFERENCE APPENDICES JA8 and JA10) Test Report
For
LEDVANCE LLC

(Brand Name: SYLVANIA)

200 BALLARDVALE STREET WILMINGTON, MA 01887

Model name(s):
LEDRT6G1000SC3

**Type of
Luminaire:**

Directional downlights

Report Date:

2021-11-15

Ningbo TengLi Testing Co., Ltd

Prepared By:

2nd floor, Block B, Ningbo Testing and Certification Base,
No. 66 Qingyi Road, Ningbo National Hi-Tech Zone,
Ningbo, Zhejiang

Test & Report By:

Review By:

Engineer: Nick Song

Manager: Garman Mo

Note: 1. The results contained in this report pertain only to the tested samples.
2. This report does not imply product certification, approval, or endorsement by any agency of the Federal Government.

1.1 Product Information:

Model Number	LEDRT6G1000SC3
Remark	N/A
Representative (Tested) Model	LEDRT6G1000SC3
SKU (if available)	N/A
Type of Lamp	Directional downlights
LED Manufacturer	Bridgelux, Inc.
LED Model	BXFN-XXG-13H-98
Dimming	Dimmable
Sample Number	STD210933NB-C1-C3

1.2 Rated Values:

The Rated Values		
Rated Voltage / Frequency	120Vac,60 Hz	
Nominal Power	13W	
Rated Initial Lamp Lumen	--	
Dimming range	10%-100%	
Target Replacement Wattage	--	
Declared CCT	2700K/3000K/3500K/4000K	
Luminaire Aperture (for Downlight Retrofits)	--	in.
Luminaire Length	--	mm
Luminaires Width	--	mm
Number of Units (modular products)	N/A	s
Product Photo		

Product Photo



1.3 Test Specifications:

Date of Receipt	Oct.10,2021
Date of Test	Oct.11,2021
1.Test Method according to 10 CFR 430 Appendix BB to Subpart B, Uniform Test Method for Measuring the Input Power, Lumen Output, Lamp Efficacy, Correlated Color Temperature (CCT), Color Rendering Index (CRI), Power Factor, Time to Failure, and Standby Mode Power of Integrated Light-Emitting Diode (LED) Lamps	
2.Standards used: IES LM-84-14 Approved Method for Measuring Luminous Flux and Color Maintenance of LED Downlight Retrofits, Light Engines, and Luminaires	
3.The ambient temperature during maintenance test of the DUT between photometric measurements shall be maintained at 25°C ± 5°C. Humidity: < 65 RH. Airflow shall be minimized.	
4. Supply rated input voltage (e.g. 120V) and frequency (60Hz) to the samples. Branch circuit input voltage shall be regulated to within ≤ 2% of the rated rms value. The input voltage to each DUT or driver shall be verified periodically.	
5. Conduct minimum 6000 hours life test, conduct LM-79 test measurement in 1000-hour interval.	
6. At each measurement interval, the DUT shall be taken off the test racks and measured per IES LM-79-08 for electrical, photometric, and colorimetric characteristics. After measurement, the DUT shall be placed back on the test rack for the next cycle if required.	
7. Chromaticity parameters were measured using an integrating sphere, a spectroradiometer and software. The ambient temperature condition inside the sphere was maintained at 25° C ± 1° C. The sample measurements were made using a spectroradiometer connected by a fiber optic cable and detector through the detector port of the integrating sphere. The sample was operated at 120 or rated Volts AC, 60Hz. It was stabilized before measurement was made. Chromaticity coordinates, correlated color temperature and color rendering index were calculated from the spectral power distribution taken at 5 nm intervals over the range of 380 to 780 nm.	
8. Electrical parameters were measured using power meters incorporated in goniophotometer or sphere-spectroradiometer system. The ambient temperature surrounding the sample was maintained at 25° C ± 1° C. The sample was operated at 120 or rated Volts AC, 60Hz. It was stabilized before measurement was made. Voltage, frequency, current, power, power factor and total harmonic distortion were measured by and read from the power meter.	
9. Off state power measurement – accordance to IEC 62301	

2.1 Summary of Test Result

Criteria Item	Requirement	Measured Value	Status
Light Source Type	LED, OLED, Fluorescent, HID, Incandescent, Other	LED	Pass
Product type	Omnidirectional lamp, Directional lamp, Decorative lamp, LED light engine, inseparable SSL luminaire, T20 lamp, other	Directional downlights	Pass
Luminous Efficacy	≥ 45 lumens/Watt	88.73lm/W	Pass
Power Factor	≥ 0.90	0.9778	Pass
Start time	≤ 0.5 sec	367ms	Pass
Correlated Color Temperature (CCT)	≤ 4000 Kelvin	2799	Pass
Color Rendering Index (CRI)	≥ 90 for all products other than T20 lamps, ≥ 82 for T20 lamps	91.9	Pass
Color Rendering R9 (red)	≥ 50 for all products other than T20 lamps	68	Pass
Rated life	$\geq 15,000$ hours	50000	Pass
Minimum dimming level	$\leq 10\%$	3.17%	Pass
Flicker	$< 30\%$ for frequencies of 200 Hz or below, at 100% and 20% light output	See Below Test Data	Pass
Audible Noise	≤ 24 dBA	16.9	Pass

2.2 Initial Electrical and Light Output Measurement (Refer to Work Instruction QD25)	[✓] IES LM-79 (2008) [✓] ANSI C82.2:2002
--	---

Test date	2021-10-11	Test Ambient:	25±1 °C
Test Orientation	As intended	Stabilization Time (min)	45
Model Number	LEDRT6G1000SC3		

Electrical Measurement:

Sample No.	Voltage (Vac)	Frequency (Hz)	Current (A)	Power (W)	Power Factor
STD210933 NB-C1	120.1	60.01	0.1045	12.27	0.9778


Chromaticity Measurement - Sphere-Spectroradiometer Method:

Parameter	Result
Test Voltage (V)	120.0
Frequency (Hz)	60
CCT (K)	2799
Duv	0.0023
Chromaticity (x, y)	x=0.4557 y=0.4157
Chromaticity (u', v')	u'=0.2575 v'=0.5287
Color Rendering Index (CRI)	91.9
R9	68

Goniophotometer Method:

Parameter	Result
Test Voltage (V)	120.0
Frequency (Hz)	60
Total Luminous (lm)	1088.9
Luminous Efficacy (lm/W)	88.73

Zonal Lumen Tabulation



Zonal Lumen Summary		
Zone	Lumens	% Luminaire
0-30	711.4	65.4%
0-40	903.4	83%
0-60	1,049.2	96.4%
60-90	39.3	3.6%
70-100	14.4	1.3%
90-120	0.0	0%
0-90	1,088.6	100%
90-180	0.0	0%
0-180	1,088.6	100%

Lumens Per Zone					
Zone	Lumens	% Total	Zone	Lumens	% Total
0-10	131.4	12.1%	90-100	0.0	0%
10-20	293.6	27.0%	100-110	0	0%
20-30	286.5	26.3%	110-120	0	0%
30-40	192.0	17.6%	120-130	0	0%
40-50	98.3	9.0%	130-140	0	0%
50-60	47.5	4.4%	140-150	0	0%
60-70	24.9	2.3%	150-160	0	0%
70-80	11.6	1.1%	160-170	0.0	0%
80-90	2.8	0.3%	170-180	0.0	0%


Table--1

UNIT: ed

C (DEG) T (DEG)	0	22.5	45	67.5	90	112.5	135	157.5	180	202.5	225	247.5	270	292.5	315	337.5	
0	1488	1488	1488	1488	1488	1488	1488	1488	1488	1488	1488	1488	1488	1488	1488	1488	
5	1427	1422	1420	1416	1412	1409	1408	1413	1424	1431	1439	1447	1453	1452	1447	1438	
10	1258	1250	1248	1247	1244	1242	1251	1270	1294	1299	1299	1306	1313	1309	1295	1280	
15	1032	1023	1020	1022	1022	1025	1041	1067	1098	1104	1099	1098	1101	1095	1078	1060	
20	809	792	793	795	792	794	807	834	874	883	875	877	882	873	855	840	
25	614	591	585	591	585	586	596	615	648	659	659	663	670	663	644	637	
30	442	427	417	423	416	416	421	433	459	466	472	477	488	482	467	461	
35	304	292	286	285	277	277	282	287	304	314	320	328	338	336	328	320	
40	199	192	189	181	174	176	180	180	186	199	208	215	221	225	223	212	
45	124	125	122	111	106	110	111	109	111	121	132	136	138	144	147	138	
50	75.9	80.4	78.8	69.1	65.9	70.1	70.1	68.0	69.0	73.5	83.9	84.9	84.1	90.8	95.0	86.3	
55	50.7	52.8	52.6	46.5	44.8	47.0	46.4	46.0	46.6	48.7	55.0	55.6	55.2	59.1	63.0	56.0	
60	35.5	36.3	35.9	32.7	31.1	32.6	32.3	31.7	32.6	34.0	37.8	38.4	38.6	40.5	42.8	38.9	
65	24.8	25.0	24.6	22.7	21.5	22.4	22.2	21.8	22.6	23.8	26.3	26.8	27.1	28.2	29.4	27.2	
70	16.4	16.4	16.0	15.2	14.5	15.0	14.9	14.9	15.5	16.3	17.8	18.3	18.6	19.0	19.4	18.0	
75	10.2	10.0	9.90	9.60	9.34	9.70	9.86	10.1	10.6	11.2	11.9	12.2	12.4	12.5	12.4	11.3	
80	5.18	5.04	5.08	5.08	5.06	5.26	5.57	5.96	6.42	6.77	7.03	7.08	7.15	7.07	6.65	5.91	
85	1.65	1.58	1.66	1.74	1.85	2.02	2.29	2.65	3.06	3.23	3.26	3.25	3.22	3.03	2.60	2.13	
90	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.01	0.10	0.17	0.09	0.01	0.00	0.00	0.00	0.00	
95	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
100	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
105	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
110	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
115	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
120	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
125	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
130	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
135	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
140	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
145	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
150	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
155	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
160	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
165	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.01	0.01	0.01	0.01	0.00	
170	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.01	0.01	0.01	0.01	0.01	0.01	
175	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.01	0.01	0.01	0.01	0.00	
180	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	

QR

Spectral Power Distribution & Chromaticity Diagram



R1 =95 R2 =93 R3 =87 R4 =93 R5 =93 R6 =91 R7 =94
R8 =88 R9 =68 R10=79 R11=94 R12=75 R13=94 R14=91 R15=92


2.3 Start Time Test

Test date	2021-10-11	Test Ambient:	25±1 °C
Test Orientation	As intended	Stabilization Time (min)	45
Model Number	LEDRT6G1000SC3		

Electrical Measurement:

Sample No.	Start Time (ms)
STD210933NB-C1	388
STD210933NB-C2	346
STD210933NB-C3	366
Average	367

Graph (Start Time):



2.4 In-Situ Temperature Measurement Test (ISTMT)

Test date	2021-10-11	Test Ambient:	25.1 °C
Test Orientation	As intended	Stabilization Time (min)	45
Model Number	LEDRT6G1000SC3		

Electrical Measurement:

Input Vol./Frequency	120 V / 60 Hz		Output Current of Single LED(mA)	79mA	
Sample No.	LED Package Model	Maximum Measured LED Ts Point Temperature (°C)	Maximum LED Ts Point Temperature Limited (°C)	Maximum Measured LED Driver Td Point Temperature (°C)	Maximum LED Driver Td Point Temperature Limited (°C)
STD210933NB-C1	BXFN-X	86.0	105	72.3	105
STD210933NB-C2	XG-13H-	85.0		72.0	
STD210933NB-C3	98	84.4		71.1	

Time (t) at which to estimate lumen maintenance (hours):	50,000
Lumen maintenance at time (t) (%):	86.25%
Reported L70 (hours):	>72000

2.5 Dimming, Reduced Flicker Operation and Audible Noise

Test date	2021-10-11	Test Ambient:	25±1 °C
Test Orientation	As intended	Stabilization Time (min)	45
Model Number	LEDRT6G1000SC3		

Electrical Measurement:

Dimmer Model	LEVITON MFG CO INC (E31373), Cat. No. 6681		
Sample No.	Input	Dimming (100%)	Dimming (<10%)
		Luminous flux (lm)	Luminous flux (lm)
STD210933NB-C1	120.0 V / 60 Hz	1060	73.34
STD210933NB-C2	120.0 V / 60 Hz	1053	52.25
STD210933NB-C3	120.0 V / 60 Hz	1049	33.21
Sample No.	Input	Dimming (100%)	Dimming (20%)
		Peak Noise Reading (dBA)	Peak Noise Reading (dBA)
STD210933NB-C1	120.0 V / 60 Hz	14.4	16.9
STD210933NB-C2	120.0 V / 60 Hz	14.7	16.3
STD210933NB-C3	120.0 V / 60 Hz	14.8	16.8

Flicker Result:

Dimming Level	100% Dimming Level	20% Dimming Level	Nominal Dimming Level
Percent Flicker (Unfiltered)	9.926%	6.354%	17.280%
Percent Flicker (1000Hz cut-off)	9.650%	14.916%	11.999%
Percent Flicker (400Hz cut-off)	9.360%	14.916%	12.193%
Percent Flicker (200Hz cut-off)	8.821%	12.300%	9.737%
Percent Flicker (90Hz cut-off)	0.213%	3.268%	2.830%
Percent Flicker (40Hz cut-off)	0.169%	3.170%	2.746%

2.6 Data comparison for different CCT setting

Test date	2021-10-11	Test Ambient:	25±1 °C
Test Orientation	As intended	Stabilization Time (min)	45
Model Number	LEDRT6G1000SC3		

Sample No.	CCT setting	Flux(lm)	P(W)	lm/W
STD210933NB-C1	2700K setting	1088.9	12.27	88.73
	3000K setting	1092	12.23	89.29
	3500K setting	1102	12.23	90.11
	4000K setting	1106	12.20	90.66

draft

3. Test Equipment

Equipment ID	Equipment Name	Last Calibration Date	Next Calibration Date
ST-R-702	2 meter Integrating Sphere	Verified by D204 standard lamp	
ST-R-701	Spectral analysis system HAAS-1200	Verified by D204 standard lamp	
ST-R-703	Standard Lamp D204	2021-02-21	2022-02-20
ST-R-704	Power Meter for Integrating Sphere	2021-01-04	2022-01-03
ST-R-714	Goniophotometer system	Verified by D908S standard lamp	
ST-R-710	Standard Lamp D908S	2021-02-21	2022-02-20
ST-R-711	Power Meter for Goniophotometer	2021-01-04	2022-01-03
ST-R-725	LFA-3000	2021-01-04	2022-01-03
ST-R-622	Oscillograph	2021-01-04	2022-01-03
Uncertainty(K=2): Photometric Measurement (Sphere):3.94% Chromaticity Measurement(Sphere):48.2K Photometric Measurement(Goniophotometer):3.96%			

***** END OF REPORT *****